

CERTIFICATE OF APPROVAL No CF 5515

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

CORINTHIAN INDUSTRIES INDONESIA

Jl. Mercedes Cicadas – Gunung Putri, Bogor 16964, Indonesia
Tel: +62 21 8670314

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT
FD30 Slab Door Assemblies

TECHNICAL SCHEDULE
TS10 Fire Resisting Door
Assemblies With Non Metallic
Leaves

Signed and sealed for and on behalf of Exova (UK) Limited trading as
Warrington Certification



Sir Ken Knight
Chairman
Impartiality Committee



Paul Duggan
Certification Manager



Issued: 24th January 2017
Valid to: 25th January 2022
Page 1 of 3



CERTIFICATE No CF 5515 CORINTHIAN INDUSTRIES INDONESIA

CORINTHIAN INDUSTRIES INDONESIA FD30 TIMBER DOOR ASSEMBLIES

This approval relates to the use of the above doors in providing fire resistance of 30 minutes insulation and 30 minutes integrity as defined in BS 476: Part 22. Subject to the undermentioned conditions, the doors would be expected to meet the relevant requirements of BS 9999 for FD30 door assemblies when used in accordance with the provisions therein.

1. This certificate is designed specifically to demonstrate compliance of the product or system with Approved Document B (England and Wales); the Technical Handbooks (Scotland); Technical Booklet E (N. Ireland). If compliance is required with other regulatory or guidance documents there may be additional considerations or conflicts to be taken into account.
2. The doors are approved on the basis of:
 - i) Initial type testing
 - ii) A design appraisal against TS10
 - iii) Inspection and surveillance of factory production control
 - iv) Certification under a CERTIFIRE approved Quality Management System
 - v) Audit testing in accordance with TS10
3. The doors comprise cellulosic cored leaves with hardwood lippings in various finishes for use with timber frames, with intumescent edge seals (ITT FD30).
4. This approval is applicable to both complete door assemblies and door leaves. Where the door is not supplied in a fully fitted form it is a condition of this approval that an agreed Data Sheet accompanies the product and is complied with in its entirety. Failure to do so will invalidate this approval and may jeopardise the fire performance of the door.
5. This approval is applicable to latched and unlatched, single-acting, single-leaf, ITT assemblies, at leaf dimensions up to those given in Table 1:

Door assembly configuration	Maximum Height (mm)	Maximum Width (mm)	Area (m ²)
Single-Acting, Single-Leaf Latched / Unlatched	2100 (at 926 wide)	926 (at 2100 high)	1.94

Table 1

Note: Under no circumstances must either the maximum height or maximum width be exceeded without separate CERTIFIRE approval.

CERTIFICATE No CF 5515

CORINTHIAN INDUSTRIES INDONESIA

CORINTHIAN INDUSTRIES INDONESIA FD30 TIMBER DOOR ASSEMBLIES

6. Hardware items, including closing devices and intumescent fire seals, shall be as specified in the Data Sheet.
7. The door assembly shall be mechanically fixed to wall constructions having a fire resistance of at least 30 minutes.
8. Labels to the CERTIFIRE design, or approved by CERTIFIRE, referencing CERTIFIRE and CERTIFIRE Ref. No. CF5515 and FD30 classifications resistance shall be affixed to each door in the prescribed position.
9. This approval relates to on-going production. The product and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application when appropriate.

CORINTHIAN INDUSTRIES INDONESIA FD30 TIMBER DOOR ASSEMBLIES CF 5515 DATA SHEET

1. General

This door leaf has been fire tested and is certified by CERTIFIRE as being capable of providing fire resistance of 30 minutes integrity and 30 minutes insulation as defined in BS 476: Part 22, when installed in accordance with the following conditions. Subject to these, the door will meet the relevant requirements of BS 9999 for FD 30 when used in accordance with the provisions therein.

In recognition of this, the leaf carries a prefixed label on the top or hanging edge of the door, issued under the terms of the CERTIFIRE scheme. This label uniquely identifies the door leaf, the manufacture of which complies with a CERTIFIRE approved Quality Management System and is subject to on-going surveillance. This label shall not be removed.

It is emphasised that the certification is conditional upon the following instructions being complied with in their entirety. Failure to do so will invalidate this approval and may jeopardise the fire performance of the door. Door assemblies supplied pre-fitted with components by Corinthian Industries Indonesia may be considered to meet the requirements in respect of those items.

2. Door Leaf Dimensions

This approval is applicable to single-action, single-leaf, latched and unlatched, assemblies at leaf dimensions up to those detailed within Table 1 below:

Door assembly configuration	Maximum Height (mm)	Maximum Width (mm)	Area (m ²)
Single-Acting, Single-Leaf Latched / Unlatched	2100 (at 926 wide)	926 (at 2100 high)	1.94

⁽¹⁾ Under no circumstances must the maximum height, maximum width or maximum area be exceeded without separate CERTIFIRE approval.

3. Door Frame

To be any of the following:-

- | | | |
|---|-----------------|--|
| Softwood or Hardwood
(Excluding Ash, Beech,
Towri, Iroko and
Gerrongang) | i) Density: | 450 kg/m ³ min. |
| | ii) Dimensions: | 77 mm by 25 mm min. |
| | iii) Door Stop: | 12 mm deep by 25 mm wide pinned,
screwed or rebated from solid.

Min. 38 mm long pin fixings required.

Where rebated from solid the min overall
section size is to be increased to 77 mm
by 37 mm min.

Minimum stop density 450 kg/m ³ . |



MDF	i) Density: 720 kg/m ³ min. ii) Dimensions: 77 mm by 25 mm min. iii) Door Stop: 12 mm deep by 25 mm wide pinned, screwed or rebated from solid. Min. 38 mm long pin fixings required. Where rebated from solid the min overall section size is to be increased to 77 mm by 37 mm min. Minimum stop density 720 kg/m ³ .
Jointing:	Mortice and tenon, mitred or half lapped joints with the head screw fixed to the jambs using two steel screws
Door to frame gaps:	Not to exceed 4 mm except at threshold where up to 6 mm is

4. Supporting Construction

The door assemblies are approved to be installed in brick, block, masonry, timber or steel stud of minimum thickness 72 mm, providing at least 30 minutes fire resistance. Where stud partitions are used these should be suitably constructed to provide a secure fixing for the door assemblies as recommended by the partition manufacturer.

5. Installation

The opening may be lined with softwood or hardwood which shall be continuous and of minimum width, 70mm. Each door frame jamb to be fixed through to the wall at not less than four points with steel or nylon fixings at maximum 600 mm centres penetrating the wall to at least 50 mm. Architraves are optional with no restrictions on material, size or fixing.

Door assemblies shall be installed as stated in BS 8214. Suitable CERTIFIRE approved lineal gap sealing systems may also be utilised to protect the frame/supporting construction gap, subject to the conditions contained within the relevant certificate.

The use of third party accredited installers provides a means of ensuring that installations have been conducted by knowledgeable contractors, to appropriate standards, thereby increasing the reliability of the anticipated performance in fire.

Door leaves may be trimmed to fit the frame by the following maximum amounts:

- Stiles (each): 4 mm
- Bottom: 6 mm

Note that the maximum door to frame and door to threshold gaps specified shall not be exceeded, nor shall the door edge fitted with the CERTIFIRE label be trimmed since removal of the label will invalidate the certification.

The labelled edge may be subjected to minor 'shooting-in', providing the label is not damaged or removed in the process, and the amount of material removed does not exceed that stated previously.

6. Glazed Apertures

Not permitted



7. Intumescent Seals

CERTIFIRE certificated intumescent seals are required to be fitted to these doors as below.

For door assemblies to BS476: Part 22 – classified as FD30

Door assembly Configuration*	Position	Required Intumescent Protection
Single-acting, Single-leaf door assemblies latched / unlatched	Frame Head or Top edge of Leaf	Single 15 mm wide by 4 mm thick Therm-A-Seal by Intumescent Seals Ltd. Intumescent to be positioned centrally
	Frame Jamb or Vertical edges of Leaf	Single 15 mm wide by 4 mm thick Therm-A-Seal by Intumescent Seals Ltd. Intumescent to be positioned centrally

Seals may be interrupted at hinge and latch positions.

Alternative seals may be utilised in-line with the relevant CERTIFIRE approval for the proposed intumescent seal. All seals to be CERTIFIRE approved (to Technical Schedule 35).

Smoke seals may be included subject to the conditions contained within the relevant CERTIFIRE certificate for the smoke seal.

8. Hinges

Hinges shall be CE marked against EN 1935 for use on 30 minute timber fire door assemblies.

Number:	Minimum 3 No.
Type:	Steel lift off or butt hinges.
Positions:*	Maximum 200 mm from the top of door to top hinge. Maximum 300 mm from the bottom of door to bottom hinge. Middle hinge fitted centrally in the leaf height.
Dimensions:	i) Height: 80 - 100 mm ii) Blade width: 30 - 36 mm iii) Thickness: 3 mm (+/- 0.5 mm) iv) Knuckle dia.: 14 mm (+/- 1 mm)
Fixings:	Minimum 4No. steel screws per hinge blade. Screw length varies to suit frame material see details below: Softwood frame: Minimum No.8 by 32 mm long screws. Hardwood frame: Minimum No.8 by 32 mm long screws. MDF frame: Minimum No.8 by 25 mm long screws.
Intumescent Protection**	None required.

* The datum in all cases is the centreline of the hinge.

** This specification overrides any requirement for additional intumescent identified in the hinge manufacturer's certification providing the hinge specification falls within the parameters identified above, specifically maximum dimensions and material. Where alternative hinges exceed the specification given above the intumescent protection as identified in the hinge manufacture's CERTIFIRE certificate shall apply.

Any other CERTIFIRE approved hinges may be used, subject to the conditions contained within the relevant certificate.



9. Locks and Latches

Locks / latches are not necessary. When fitted locks / latches shall be CE Marked for use on 30 minute timber fire doors.

Mortice type, automatic (sprung) latch bolt, cylinder rim nightlatches and knobsets.

Max. case dimension:	120 mm high by 90 mm deep by 19 mm wide
Max. forend dimension:	160 mm high by 25 mm wide
Max. keep dimension:	160 mm high by 25 mm wide (excluding latch plate)
Latchbolt material:	Steel or material with a melting point greater than 800°C
Position:	Max. 1200 mm from bottom of door to centreline of lockcase
Intumescent: protection*	None required

* This specification overrides any requirement for additional intumescent identified in the lock manufacturer's certification providing the lock/latch specification falls within the parameters identified above, specifically maximum dimensions and material. Where alternative lock/latch exceeds the specification given above the intumescent protection as identified in the lock/latch manufacture's CERTIFIRE certificate shall apply.

Any other CERTIFIRE approved lock/latch may be fitted, subject to the conditions contained within the relevant certificate.

Recessing for locks should result in a tight fit, allowing for any intumescent protection where required.

No restriction on type and material of handles.

10. Self-Closing Devices

All doors are required to be fitted with a CERTIFIRE certificated self-closing device. The exceptions are doors kept locked shut such as service access doors. Note: closers with mechanical hold-open mechanisms are not permitted to be used. Building Regulations may identify locations within domestic locations where self-closing devices are not mandatory.

11. Ancillary items

11a Protection plates and signage

Surface mounted plastic, steel, aluminium or brass plates are acceptable on the basis that they are:

- < 2mm thick
- Do not occupy more than 20% of the door leaf in total, or exceed 500mm in height for kickplates and 300mm for mid-plates, whichever is the smaller.
- Do not wrap around the vertical edges, and on the closing face do not extend beneath the door stops (generally 40-50mm narrower than door width)
- Plates/signage can be bonded with a thermally softening adhesive. Additionally screws may be used.



11b Flushbolts

Not permitted

11c Pull Handles

Screw-fixed, bolt-fixed from the back and back-to-back fixed pull handles of steel, brass, aluminium and nylon coated, are permitted providing any through-bolt fixing is of steel.

11d Air transfer grilles

Not permitted

11e Letter Plates

Not permitted

11f Door Viewers

Not permitted

11g Coat Hooks and Other Surface Mounted Hardware

Ancillary items which are wholly surface mounted may be fitted providing:

- These items are screw fixed or bonded only
- Are not bolted through the full thickness of the door

12. Further Information

Further information regarding the details contained in this data sheet may be obtained from Corinthian Industries Indonesia (Tel: +62 21 8670314).

Further information regarding the CERTIFIRE certification and other approved products can be obtained from Exova (UK) Limited trading as Warrington Certification (Tel: +44 (0) 1925 646777)

