

## BS EN 12600:2002 - Glass in building - Pendulum test - Impact test method and classification for flat glass

Report No. R20805  
Project No. 20805  
Date of Report 9<sup>th</sup> September 2019  
Date of Test 12<sup>th</sup> August 2019  
Test conducted for HomeDecor  
Innovation Way  
Woodhouse Mill  
Sheffield  
S13 9AD

Product Name 3mm Clear Float Glass with safety film backing  
Product Definition Asymmetrical  
Classification 1B1 – Glass Side Only

### Results

Class	Impacted side	Sample ID	Size (mm)		Breakage Mode	Result
			Width	Height		
3	Glass	1	876	1938	B	Pass - Did not break
3	Glass	2	876	1938	B	Pass - Did not break
3	Glass	3	876	1938	B	Pass - Did not break
3	Glass	4	876	1938	B	Pass - Did not break
2	Glass	1	876	1938	B	Pass - Did not break
2	Glass	2	876	1938	B	Pass - Did not break
2	Glass	3	876	1938	B	Pass - Did not break
2	Glass	4	876	1938	B	Pass - Did not break
1	Glass	1	876	1938	B	Pass - Did not break
1	Glass	2	876	1938	B	Pass - Did not break
1	Glass	3	876	1938	B	Pass - Did not break
1	Glass	4	876	1938	B	Pass - Did not break

Compiled By N Steventon  
Laboratory Technician



Approved By M Witkowska  
Quality Engineer



This report is copyright and reproduction of this document in whole or any part thereof must not be made without prior written permission from Wintech Engineering Ltd.

This report and the results shown within are based upon the information, drawings, samples and tests referred to in the report. The results obtained do not necessarily relate to samples from the production line of the above named company and in no way constitute any form of representation or warranty as to the performance or quality of any products supplied or to be supplied by them. Wintech Engineering Ltd or its employees accept no liability for any damages, charges, cost or expenses in respect of or in relation to any damage to any property or other loss whatsoever arising either directly or indirectly from the use of the report.

Wintech Engineering Ltd, Halesfield 2, Telford, Shropshire, TF7 4QH - Tel: +44 (0)1952 586580 - Web: [www.wintechtesting.com](http://www.wintechtesting.com)