kiwa

Partner

Progress

for

Field of Application Report

IFC Report PAR/10899/01 Revision H

Fire Resistance Standard: BS476: Part 22: 1987



PKF Global Ltd

Assessed Product/System:

Three-Layer Particleboard Leaves, With or Without Feature Grooves, Installed in Timber Frames

Assessed Performance:

30 Minutes Fire Resistance

Issue Date

Expiry Date

August 2022

February 2027

International Fire Consultants Ltd

Ground Floor, Suite A, Building 2 Bear Brook Office Park Walton Street Aylesbury, Buckinghamshire HP21 7GQ

+44 (0)1844 275500 uk.firesafety@kiwa.com



International Fire Consultants Ltd

International Fire Consultants is part of the **Kiwa UK Group**. The company is a specialist engineering consultancy delivering independent, honest and practical fire safety solutions to professionals across the built environment. The sought after fire safety advice protects life, preserves property and safeguards business continuity.

International Fire Consultants was established in 1985 to provide high quality and impartial technical expertise concerning fire safety. Since then the team of highly qualified Fire Engineers and Fire Safety Professionals have continued to deliver robust, innovative and cost-effective fire safety solutions, including Assessments, Designs and Inspections.

International Fire Consultants are able to lend their insight and practical expertise for: Fire Safety Engineering, Fire Risk Management, Product Evaluation, Fire Life Safety Systems, Expert Witness Testimony and Fire Protection Training, to developments of all sizes and complexities; from residential, education and healthcare structures to sporting venues, airports and iconic heritage buildings, such as historical royal palaces and stately homes.

Recognised internationally as the go-to professionals in all aspects of fire safety, International Fire Consultants is one of the world's leading fire engineering and solution providers, trusted by many of the most prestigious construction firms, architects and estate owners.

HEAD OFFICE/CORRESPONDENCE ADDRESS:	REGISTERED ADDRESS:
Ground Floor, Suite A, Building 2	International Fire Consultants Limited
Bear Brook Office Park	UK Group
Walton Street	Kiwa House
Aylesbury, Buckinghamshire	Malvern View Business Park
HP21 7GQ	Stella Way, Bishops Cleeve
	Cheltenham
	GL52 7DO

+44 (0)1844 275500 uk.firesafety@kiwa.com Registered No: 2194010

Private and Confidential

This report should not be manipulated, abridged or otherwise presented without the written consent of International Fire Consultants.

Report Reference Number:	IFC Report PAR/10899/01 Revision H
Prepared on behalf of:	PKF Global Ltd
Address:	Unit 2, Devonshire Business Park
	Chester Road
	Borehamwood
	Hertfordshire
	WD6 1NA
Issue Date:	August 2022
Issue Date:	February 2027
Ref ID:	#23570



Issue and Amendment Record

REV	DATE	AUTHOR	REVIEW	SECTION	AMENDMENTS
-	November 2011	PG	DC	-	_
А	December 2013	PP	DC	All	Inclusion of additional groove detail and MDF frames
В	February 2015	PP	DC	-	Inclusion of alternative lipping detail
С	December 2015	DC	DI	All	Inclusion of additional door designs and associated changes
D	June 2019	MB	СРН	All	Review and Revalidation. Update to current IFC format. Revised scope to suit latest industry protocols. Additions and edits following client comments. Add diagonal grooves and Figure for Holdenby design.
E (#15430)	September 2019	MB	СРН	Sections 4.5, 4.8 and Appendix B	Addition of approval for Pyroguard C730 glass, and Sealmaster Foam Glazing Tape. Minimum thickness of softwood frames reduced to 30mm. Addition of approval for letter plates.
F (#20999)	February 2022	СРН	DC	All	Review and Revalidation. Update to current IFC format. Revised scope to suit latest industry protocols. Incorporation of additional test evidence
G (#20999)	April 2022	СРН	DC	Section 4.5	Slight amendment to the feature groove parameters
H (#23570)	August 2022	СРН	DC	All	Update to current IFC format and alternative door frame and lock specification added from test CFR1611081



Contents

1.	Intr	oduction	5
2.	Test	Evidence	5
3.	Sco	pe of Approval	6
	3.1	Door Assembly Configurations	6
	3.2	Maximum Assessable Door Leaf Sizes	6
4.	Doc	r constructional details	7
2	4.1	Leaf Construction	7
2	1.2	Door Lippings	8
2	1.3	Decorative Leaf Facings	9
2	1.4	Decorative Leaf Finishes	10
2	1.5	Feature Grooves	10
2	1.6	Transommed Overpanels	15
2	1.7	Door Frames	16
2	1.8	Glazed Apertures	20
2	1.9	Hardware	24
2	4.10	Installation and Supporting Construction	24
2	4.11	Gap Sealing	25
2	4.12	Intumescent Seals	27
Z	4.13	Ambient Temperature Smoke Seals	27
5.	Lim	tations	28
6.	Vali	dity	29
7.	Dec	laration by the Applicant	30
Ар	pendi	x A Leaf Size Envelopes and Intumescent Specifications	31
Ар	pendi	x B Installation of hardware	36
Ap	pendi	x C Summary of fire test evidence	40



1. Introduction

This report has been prepared by International Fire Consultants Ltd (IFC), on the instruction of PKF Global Ltd, to define the Field of Application for the three-layer particleboard leaves, with or without feature grooves, installed in timber frames, that are required to provide 30 minutes fire resistance performance, when adjudged against BS476: Part 22: 1987.

This assessment has been produced using the principles outlined in the Passive Fire Protection Forum (PFPF): 'Guide to Undertaking Technical Assessments of the Fire Performance of Construction Products Based on Fire Test Evidence, 2021, Industry Standard Procedure'.

When establishing the variations in the construction that can achieve the required fire resistance performance, IFC complies with the principles found in the following documents:

- BS ISO/TR 12470-2: 2017 'Fire resistance tests Guidance on the application and extension of results from tests conducted on fire containment assemblies and products. Part 2: Non-load bearing elements'.
- EN 15725: 2010 'Extended application reports on the fire performance of construction products and building elements'.

It is proposed that variations to the tested specifications, as described in the following sections, may be accommodated into door assemblies, without reducing their potential to achieve a 30 minute integrity rating, if tested in accordance with the method and criteria of BS476: Part 22: 1987.

The omission of information on any components or manufacturing methods does not imply a lack of approval of those details, but these would need to be the subject of a separate analysis. Only variations specifically mentioned are supported by this assessment document, all other aspects must otherwise be as proven in tests summarised herein.

It is more onerous to test timber door assemblies, hinged or pivoted, with the specimen installed with the leaf opening in towards the furnace. Testing in this orientation is therefore incorporated into Field of Application Reports to cover doors opening in the opposite direction. The principle is only applicable when the door construction, and any features within the door leaf, such as glazing, are symmetrical.

Unless stated otherwise, herein, this Field of Application considers the scope of approval for door assemblies that may be installed in either orientation, that being with either face exposed to fire conditions.

2. Test Evidence

The test evidence used to support this Field of Application Report is summarised in Appendix C of this report.

Some of the test evidence referenced in this Engineering Assessment Report is more than 5 years old. In accordance with industry practice, IFC have reviewed this test evidence, and have concluded that the evidence is still valid, and suitable to form the basis of this approval.



3. Scope of Approval

3.1 Door Assembly Configurations

GENERAL REQUIREMENTS/NOTES

- The table below provides an overview of the approved door assembly configurations when using a typical FD30 three-layer particleboard leaf, with or without feature grooves, installed in timber frames.
- Figures A01 to A04 in Appendix A outline the full scope of door assembly configurations approved by this report.
- Optional transomed overpanels are permitted across all of the door assembly configurations approved for use with timber door frames.

CONFIGURATION	
DESCRIPTION	CODE
Latched, Single Acting, Single Leaf (With or Without Transommed Overpanel)	LSASD
Unlatched, Single Acting, Single Leaf (With or Without Transommed Overpanel)	ULSASD
Latched, Single Acting, Double Leaf (With or Without Transommed Overpanel)	LSADD
Unlatched, Single Acting, Double Leaf (With or Without Transommed Overpanel)	ULSADD

3.2 Maximum Assessable Door Leaf Sizes

This Field of Application Report is based on fire resistance tests conducted on the FD30 three-layer particleboard leaf, with or without feature grooves, which have been analysed using the empirically derived, non-construction specific methodologies which form the basis of IFC's analysis. These methodologies allow the data obtained from the fire test evidence to be evaluated to determine permissible door leaf sizes, without any additional enhancements.

The calculated envelopes of assessed leaf dimensions for each door assembly configuration covered by this Field of Application report are given in Appendix A.

Double door assemblies may each be of the same width, up to the maximum width indicated in Appendix A. For unequal pairs there is no limit on the ratio of leaf widths, (although the large leaf must still be within the limitations in Appendix A). The width of the small leaf shall not be less than 250mm, since this will affect its vertical stability relative to that of the larger leaf.



4. Door constructional details

Constructional specifications for the FD30 three-layer particleboard leaf, with or without feature grooves, can be found in the tables below.

Timber must have a minimum measured density at 12% moisture content. The timber must be straight grained and of appropriate quality in accordance with BS EN 942: 2007. The moisture content shall be $11 \pm 2\%$ for UK market, (or to suit internal joinery moisture content specification of export countries).

4.1 Leaf Construction

4.1.1 Leaf Thickness

MINIMUM LEAF THICKNESS

44mm

ADDITIONAL REQUIREMENTS/NOTES

- The dimension above excludes the thickness of the decorative leaf facings detailed in Section 4.4
- There are two alternative options for the leaf construction, both of which are covered by the same leaf size envelopes in Appendix A
- The maximum leaf sizes referenced in Appendix A assume that each layer of core, (and facings in Option 1), shall be formed from one piece, and joints shall not be used to achieve an increase in leaf height /width. If the core/facing materials are not available at a size to suit the maximum leaf sizes defined in Appendix A, then a reduced leaf size will be determined by the available core/facing materials

4.1.2 Option 1

COMPONENT		MATERIAL	DIMENSIONS	MINIMUM DENSITY
Coro	Inner layer	Darticloboard	13mm thick	EEOka/m ³
Core	Outer layers	Particlepoard	13mm thick	550kg/m ³
	Facings	MDF	2.5mm thick	700kg/m ³
	Between layers of core	PVA adhesive		
Adhesives	Facings	Urea formaldehyde or PVA adhesive	-	-



4.1.3 Option 2

C	COMPONENT	MATERIAL	DIMENSIONS	MINIMUM DENSITY
Coro	Inner layer	Dartialahaard	12mm thick	EEOka/m ³
Core	Outer layers	Particleboard	15.5mm thick	SSUK8/III
Adhesives	Between layers of core	PVA adhesive	-	-

4.2 Door Lippings

4.2.1 General

LOCATION	MATERIAL	MINIMUM DENSITY	MINIMUM THICKNESS	PROFILE	LIPPING ADHESIVE
Vertical leaf edges	Solid and finger-jointed hardwood	640kg/m³	Refer to Section 4.2.2	Refer to Section 4.2.2	Urea formaldehyde, PVA or vinyl urethane-based
Door leaf horizontal and overpanel edges	Solid or finger-jointed hardwood	640kg/m³	Refer to Section 4.2.2	Refer to Section 4.2.2	Urea formaldehyde, PVA or vinyl urethane-based

ADDITIONAL REQUIREMENTS/NOTES

- Lippings must be installed on all four leaf edges
- Installed lippings may be reduced in thickness for site installation purposes, provided the minimum lipping thickness detailed in Section 4.2.2 is maintained
- There must be no gaps present between the stiles/rails and the lippings
- Lippings may be concealed under the MDF facing (in option 1 design) or by the decorative facings (both option 1 and 2 designs), or be exposed (both option 1 and option 2 designs)



4.2.2 Lipping Thicknesses and Edge Profiles



4.3 Decorative Leaf Facings

COMPONENT/AREA	MATERIAL	MAXIMUM THICKNESS
Leaf faces only	Timber Veneer	2mm
	High Pressure Laminate	2mm
	PVC Laminates (e.g. Acrovyn)	2mm
	Paper	1mm
	Decorative Foil	0.5mm

ADDITIONAL REQUIREMENTS/NOTES

- Decorative facing materials must not be applied to the leaf edges
- With the exception of push/kick plates (See Appendix B.5), metallic facings are not permitted



4.4 Decorative Leaf Finishes

COMPONENT/AREA	MATERIAL	MAXIMUM THICKNESS
Leaf faces and leaf edges	Paint	
	Lacquer	0.5mm, or a maximum of 5 coats
	Varnish	winenever is greater.

4.5 Feature Grooves

The proposed door leaf designs can incorporate feature grooves machined into both leaf faces

4.5.1 Option A - With Hardwood Inserts (Can be Used With Door Option 1 or 2)

Typical Feature	e Groove Profiles		
Up to 10mm		Up to 10mm Jp to 7mm	
Maximum	Harwood Insert	24mm wide x 10mm thick	12mm wide x 8mm thick
Size	Feature groove	10mm wide x 7mm deep	8mm wide x 4mm deep
Groove Quantity/ Orientation /Margins	Vertical Grooves Horizontal Grooves	Maximum 4no. grooves which may extended edges <u>Or</u> Maximum 6no. grooves which must <u>not</u> leaf edges but stop 100mm from the hor In both circumstances, the vertical groop in from the vertical leaf edges and minim Maximum 6no. which must <u>not</u> extended stop 90mm in from the vertical leaf edges horizontal leaf edges and minimum 275m	end to the top and bottom leaf extend to the top and bottom rizontal edges ves must be a minimum 90mm num 50mm apart to the vertical leaf edges, but s – minimum 90mm in from the mm apart
Approved Leaf Size and Configurations		Approved for inclusion on unlatched and double leaf configurations on all leaf size Application Report	nd latched, single and latched, zes covered within this Field of
Additional Notes		 Horizontal and vertical grooves may a Hardwood inserts adhered in place u Hardwood for inserts can be solid or density of 750kg/m³ Grooves for the hardwood inserts are face, either before or after the decording the solid or after the solid or after the decording the solid or after the solid or after the decording the solid or after the solid or	intersect each other sing PVAc adhesive finger-jointed with a minimum e machined directly into the leaf rative face veneer is applied
Test Evidence		CFR 2009211 + CFR1106291	



4.5.2 Option B – With Hardwood Inserts (Can be Used With Door Option 1 or 2)

Typical Feature Groove Profiles		
Up t	Up 2.5	to mm
Maximum	Harwood Insert	23mm wide x 7.5mm thick
Size	Feature groove	10mm wide x 2.5mm deep
Groove Quantity/ Orientation /Margins	Vertical Grooves	Maximum 6no. grooves. The grooves nearest the vertical leaf edges may extend to the top and bottom leaf edges, the remaining grooves to stop 90mm short of the leaf head – minimum 90mm in from the vertical leaf edges and minimum 100mm apart
	Horizontal Grooves	Maximum 6no. which must <u>not</u> extend to the vertical leaf edges, but stop 90mm in from the vertical leaf edges – minimum 90mm in from the horizontal leaf edges and minimum 350mm apart
Approved Leaf Size and Configurations		Approved for inclusion on unlatched and latched, single and latched, double leaf configurations on all leaf sizes covered within this Field of Application Report
Additional Notes		 Horizontal and vertical grooves may intersect each other Hardwood inserts adhered in place using PVAc adhesive Hardwood for inserts can be solid or finger-jointed with a minimum density of 750kg/m³ Grooves for the hardwood inserts are machined directly into the leaf face, either before or after the decorative face veneer is applied
Test Evidence		WF 350734 + CFR 2009211



4.5.3 Without Hardwood Inserts (Option 1 Door Design Only)

Typical Featur	e Groove Profile	6.5mr	n			
6n	nm	mm	1.8mm			
Maximum	Harwood Insert	Not applicable leaf facing	- grooves are machine	ed directly into the veneered MDF		
Size	Eastura graava	Rectangular	Maximum 6mm wide	x 1.5mm deep		
	reature groove	V-shaped	Maximum 6.5mm wic	le x 1.8mm deep		
Groove Quantity/ Orientation /Margins	Vertical Grooves	Maximum 4no edges <u>Or</u> Maximum 6no leaf edges but In both circums in from the ver	grooves which may e grooves which must stop 120mm from the stances, the vertical gr	not extend to the top and bottom leaf not extend to the top and bottom horizontal edges ooves must be a minimum 120mm inimum 70mm apart		
	Horizontal Grooves	Maximum 6no. which must <u>not</u> extend to the vertical leaf edges, but stop 120mm from the vertical leaf edges				
Approved Leaf Size and Configurations		Approved for inclusion on unlatched and latched, single leaf configurations and latched, double leaf configurations on all leaf sizes covered within this Field of Application Report				
Additional Notes		 Horizontal and vertical grooves may intersect each other Alternatively, a decorative plastic trim may be inserted into a maximum 2mm deep x 2mm wide groove in the leaf face which may also incorporate a decorative metal cover to the face of the trim 				
Test Evidence		CFR 1503101 and CFR 2106041 with over-run				

4.5.4 Combination With and Without Hardwood Inserts (Option 1 Door Design Only)

Typical Featur	e Groove Profile					
6	mm 1.5	5mm				
Maximum	Harwood Insert With Groove	15mm wide x 10mm thick hardwood insert recessed into the leaf core - maximum 10mm wide x 7mm deep groove				
Size	Feature Groove With No Insert	Maximum 6mm wide x 1.5mm deep				
Groove With Groove		Maximum 5no. horizontal grooves which may extend to the vertical leaf edges – minimum 180mm from the horizontal leaf edges and minimum 380mm apart				
Orientation /Margins	Feature Groove With No Insert	Maximum 4no. horizontal which may extend to the vertical leaf edges – minimum 380mm from the horizontal leaf edges Maximum 2no. vertical which may extend to the horizontal leaf edges – minimum 220mm from the vertical leaf edges				
Approved Leaf Size and Configurations		Approved for inclusion on unlatched and latched, single leaf configurations and latched, double leaf configurations on all leaf sizes covered within this Field of Application Report				
Additional Notes		 Horizontal and vertical grooves may intersect each other Hardwood inserts adhered in place using urea formaldehyde adhesive Hardwood for inserts can be solid or finger-jointed with a minimum density of 750kg/m³ Grooves for the hardwood inserts are machined directly into the leaf core prior to being faced with MDF 				
Test	Evidence	CFR 2106041 with over-run				



4.5.5 Diagonal Grooves

DIAGONAL GROOVES





4.6 Transommed Overpanels

4.6.1 Overpanel Size, Configuration and Specification

GENERAL REQUIREMENTS/NOTES

Overpanels must be of the same construction as the door leaf (refer to Section 4.1) and be lipped on all four edges with hardwood (refer to Section 4.2.2)

MAXIMUM OVERPANEL SIZE						
SINGLE DOOR ASSEMBLIES	DOUBLE DOOR ASSEMBLIES					
1500mm high	1000mm high					
FRAME MATERIAL OPTIONS	APPROVED LEAF CONFIGURATIONS					
Softwood or hardwood (Minimum density 468kg/m³)	Single or double leaf					
MINIMUM TRANSOM SIZE	TRANSOM JOINT					
70mm wide x 32mm thick	Mortice and tenon or trench joint					
Overpanel Door Leaf						

4.6.2 Overpanel Fixing

	FIXING REQUIREMENTS			
	Minimum Screw Size	5mm x 70mm		
A	Minimum Quantity of Fixings	2no. screws per overpanel edge		
	Fixing Positions	Maximum 100mm from each corner and on maximum 400mm centres thereafter		
	Fixing Penetration	Minimum 40mm of screw penetration into overpanel edge		



4.7 Door Frames

4.7.1 Head Joints

- The frame head must be secured to each jamb using 2no. minimum 5mm x 80mm screws
- In addition to screw fixings, mitred joints must also be glued with cross-linking adhesive e.g. urea formaldehyde, polyurethane or resorcinol formaldehyde





4.7.2 Specifications and Profiles



		Frame	e Material	or MDF
		Minimum	Softwood and Hardwood	468kg/m³
	kness Aness	Density	MDF	700kg/m³
	Minimum Thickne			30mm
		Minimum	Frame Depth	70mm
		Minimum	12mm	
		Ad	dditional Requirem	ents/Notes
- F The	inimum irame	• The mini excludes t	mum frame thicl he integral door st	kness detailed above op.
		• Architrave gap sealin	es are optional — re g/firestopping requ	efer to Section 4.11 for uirements



FRAME PROFILE F30/3



Frame Material	Softwood or Hardwood						
Minimum Density	450kg/m³						
Minimum Thickness	30mm						
Minimum Frame Depth	70mm						
Minimum Stop Thicknes	s 25mm						
Additional Rec	quirements/Notes						
• The minimum frame thickness detailed aborexcludes the door stop							
 The doorstop is to comprise the same material as the door frame and must fixed in place using 40mm long steel pins at maximum 300mm centres 							

Architraves are optional– refer to Section 4.11 for gap sealing/firestopping requirements

4.7.3 Split Frames

GENERAL REQUIREMENTS/NOTES

The overall frame depth may be increased by utilising split frames, but the joint between the two frame sections must not intrude into the minimum frame depth as stipulated in Section 4.7.2





4.7.4 Decorative Finishes

DECORATIVE FINISHES						
MATERIAL	MAXIMUM THICKNESS					
Paint	_					
Varnish	0.5mm, or a maximum of 5no.					
Lacquer	coats, whichever is greater					



4.8 Glazed Apertures

4.8.1 General

GENERAL REQUIREMENTS/NOTES

- The table in Section 4.8.3 outlines the permitted combinations of glass type, glazing system and bead profile
- The maximum permitted glazed aperture dimensions are detailed within this table
- Corresponding aperture widths/heights will need to be adjusted until the proposed aperture area falls within the maximum aperture area detailed within this table
- The maximum aperture width and maximum aperture height must not be combined, as the resulting figure will always exceed the maximum permitted aperture area
- Drawings for the approved glazing bead profiles along with the required bead fixing methods can be found in Section 4.8.4
- All glass is to be installed in accordance with the manufacturer's instructions for expansion allowance, setting blocks, silicone pointing etc
- Glazed apertures greater than 0.57m² must include a 7mm hardwood (minimum density 600kg/m³) liner adhered to the inside edge of the aperture, either between the 2.5mm MDF facings, set 2.5mm back from the leaf faces or flush with the leaf faces, adhered in position using either PU or UF adhesive

4.8.2 Aperture Margins

GENERAL REQUIREMENTS/NOTES						
	Head	155mm				
Minimum distance from	Vertical leaf edges	175mm				
ieai euges	Bottom edge	300mm				
Minimum distance between apertures*	100mm					

*Multiple apertures are permitted providing the total glazed area does not exceed that stated in Section 4.8.3.



4.8.3 Glazed Apertures – Approved glass types, glazing systems and bead profiles

		GLASS SPE	CIFICATION					DIMENSIONS		E	BEAD	TYPES	;	G	LAZING	SYSTEM	1S
Glass Reference	Glass Thickness (mm)	Glass Type	Manufacturer	Integrity (minutes)	Insulation (minutes)	Maximum Area of Single Aperture (m2)	Maximum Total Area of Multiple Apertures (m2)	Max Aperture Height x (corresponding aperture width) (mm)	Max Aperture Width x (corresponding aperture height) (mm)	B30/1	B30/2	B30/3 - MDF Beads	Mock Glazing Beads	Interdens – 10 x 2mm (Various)	Therm-A-Strip – 10 x 2mm Intumescent Seals Ltd	Therm-A-Glaze 45 – 10 x 2mm Intumescent Seals Ltd	Ceramic fibre tape – 13 x 3mm (Various)
G1	7	Pyroshield II	Pilkington	30	NPD	0.57	0.57	1629 (x 348)	474 (x 1195)	\checkmark	×	×	×	\checkmark	\checkmark	\checkmark	×
G2	7	Pyroguard C730	Pyroguard	30	NPD	0.66	0.89	1051 (x 629)	857 (x 771)	\checkmark	×	×	×	\checkmark	\checkmark	\checkmark	×
G3	7	Pyrobelite	Pilkington	30	NPD	0.89	0.89	1913 (x 464)	632 (x 1404)	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark
G4	7.5	Pyrodur EW30-105	Pilkington	30	NPD	0.89	0.89	1913 (x 464)	632 (x 1404)	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark
G5	7	Pyrosec EW 30/7 7	Promat Securiglass	30	NPD	0.89	0.89	1913 (x 464)	632 (x 1404)	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark



4.8.4 Glazing Bead Profiles and Glazing Bead Fixings





BEAD MATERIAL Hardwood (Minimum density 640kg/m³) BEAD FIXINGS 1.9mm x 50mm steel pins or 4mm x 50mm steel screws FIXING POSITIONS Max 150mm centres and 50mm from corners 30 degrees relative to the plane of the glass GLAZING SYSTEM Refer to Section 4.8.3 ADDITIONAL REQUIREMENTS/NOTES

None





'MOCK' GLAZING BEAD	BEAD MATERIAL				
Glass types G3, G4 ¢ G5	Hardwood (minimum density 640kg/m ³)				
Double sided tape	BEAD FIXINGS				
Double sided tape Hardwood ladder glazing bead	 2no. 1.2mm x 40mm steel pins, securing the end of each glazing bar to the perimeter beads Or Double sided tape affixing the 'mock' beads to the face of the glass without any additional pin fixings at either end of the glazing bar				
	PIN FIXING POSITIONS (WHEN USED)				
	 22mm centres either end of the glazing bar 30 degrees relative to the plane of the glass				
	GLAZING SYSTEM (OPTIONAL)				
Or	Refer to Section 4.8.3				
<u> </u>	ADDITIONAL REQUIREMENTS/NOTES				
Glass types G3, G4 ¢ G5 Double sided tape Hardwood ladder glazing bead	None				



4.9 Hardware

Hardware items which are approved for use with the FD30 three-layer particleboard leaf, with or without feature grooves, are detailed in Appendix B of this report.

All hardware items must be installed in accordance with the manufacturer's instructions, except where specific installation requirements or limitations have been detailed by IFC.

4.10 Installation and Supporting Construction

SUPPORTING CONSTRUCTION

The supporting construction may be timber or steel stud plasterboard partition, blockwork, brickwork or concrete walls, but shall be of a type that has been tested or assessed to provide in excess of 30 minutes fire resistance, at the required size, when incorporating door openings. If fitted into timber or steel stud partitions, the method of forming the door assembly aperture must be as tested by the partition and/or door assembly manufacturer.

Note Any reference to steel stud partitions is in the context of permanent elements, such as those designed and proven by the plasterboard manufacturers – this report does not approve use of the proposed door assemblies in proprietary 'demountable' partitions, which must be subject to a full and independent appraisal of the particular system and door assemblies therein.

DOOR FRAME FIXING REQUIREMENTS

Timber door frames must be fixed back to the supporting construction with steel fixings at centres not exceeding 600mm on the vertical edges (minimum 200mm from the top and bottom), and a minimum of one fitted centrally across the width of the frame head of double doors. Screws shall be of sufficient length to remain secure into the supporting construction during exposure to fire, and shall be positioned such that they are not exploited by charring of the frame. Therefore, screws must be located a minimum of 20mm in from the frame edge, unless a twin line of screws is used.

DOOR FRAME PACKERS

Packers shall be used at all fixing positions, although if combustible packers are employed, they must be cut short and be capped with a layer of approved mastic and maintain compliance with one of the approved back of frame sealing methods given in the following sections.

PROJECTING DOOR FRAMES/DOOR LEAVES

The approval in this report does not apply where the wall/partition includes decorative 'cladding' on the face of the fire-resisting construction, (e.g. timber panelling on battens, or plasterboard on dabs), such that any part of the frame is aligned within the plane of this decorative cladding.

ARCHITRAVES

Where the face of the frame is flush with the face of the wall, loose architraves are optional, and have no fire performance requirements, and so can be freely specified, subject to suitable gap sealing fire stopping as detailed in Section 4.11.2.



DOOR EDGE GAPS							
	Between Leaf & Frame	Leaf Meeting Stiles	Bottom of Door (Fire)	Bottom of Door (Fire & Smoke)			
Gap Width 1.5mm to 4mm 6mm 3mm*							
*Gaps in excess of 3mm are permissible provided a suitable smoke seal is included							

DOOR LEAF ALIGNMENT

The door assembly design shall be such that when closed, single acting leaves are fully flush with the face of the frame and the face of leaves in double door assemblies shall be flush with each other at meeting stiles when closed.

4.11 Gap Sealing

4.11.1 General

GENERAL REQUIREMENTS/NOTES

• Gap sealing products must meet <u>all</u> of the requirements detailed in Section 4.11.2





4.11.2 Gap Sealing Products – Requirements for Approval

	GENERAL REQUIREMENTS							
Gap sealing products used in conjunction in accordance with BS476: Part 22: 1987 of	with the FD30 three-layer par or BS EN 1634-1: 2014. In ad	ticleboard leaf, with or without feat dition, they must meet all of the req	ure grooves, must have been success uirements detailed below;	sfully fire tested for 30 minutes fire resistance				
		FIRE TEST PRESSURE REGIM	1E					
Must have been successfully fire tested w	hen sealing a gap located ab	ove the neutral pressure axis						
		SUPPORTING CONSTRUCTION	DN					
Must have been successfully fire tested w is being used.	hen sealing a linear gap betw	veen the rear of a timber frame and	a steel/timber stud partition, or be	representative of the substrate into which it				
		GAP SIZE						
Must have been successfully fire tested w	hen sealing a linear gap, equ	al to, or larger than, that proposed.						
		SEALANT DEPTH						
Must be applied to a depth, equal to, or g	reater than, that used when	it was fire tested and finish flush wit	th the outer face of the door frame.					
BACKING MATERIAL								
TESTED BACKING MATERIAL		PERMITTED	BACKING MATERIAL OPTIONS					
No backing material included	None	CC Polyethylene backing rod	Expanding FR PU foam*	Mineral rock fibre				
Closed cell polyethylene backing rod		CC Polyethylene backing rod	Expanding FR PU foam*	Mineral rock fibre				
Expanded FR PU foam			Expanding FR PU foam*	Mineral rock fibre				
Mineral rock fibre				Mineral rock fibre only				
* Must have been successfully fire tested when sealing a linear gap between the rear of a timber frame and a steel/timber stud partition, or be representative of the substrate into which it is being used.								
		ARCHITRAVES						
TESTED ARCHITRAVE MATERIAL		PERMITT	ED ARCHITRAVE MATERIAL					
No architraves fitted	None fitted	MDF	Softwood	Hardwood				
MDF		MDF		Hardwood				
Softwood			Softwood	Hardwood				
Hardwood	Hardwood Hardwood							



4.12 Intumescent Seals

INTUMESCENT SEAL TYPE	APPROVED MANUFACTURER/SUPPLIER	SIZE/POSITIONS
PVC encased graphite-based (e.g. Mann McGowan, Pyroplex or Astroflame) or Lorient 617 type seals	From any member of the Intumescent Fire Seals Association (IFSA) or from a company with Third Party Certification from a body such as IFC Certification Ltd	Refer to Appendix A

ADDITIONAL REQUIREMENTS/NOTES

Intumescent protection is also required to specific items of building hardware – refer to Appendix B

4.13 Ambient Temperature Smoke Seals

Smoke seals that have been tested in accordance with BS EN 1634-3: 2004 (ambient temperature) or BS476: Part 31: Section 31.1: 1983 and shown not to leak by more than $3m^3/m/hr$ at 25Pa may be used in conjunction with the proposed door assemblies to provide smoke control.

The orientation of the seals, door edge gaps, degree of hardware interruption, and leaf configuration, will need to be as tested in accordance with BS EN 1634-3: 2004 (ambient temperature) or BS476: Part 31: Section 31.1: 1983 to achieve the desired level of smoke control.

Test evidence to BS476: Part 22: 1987 shall be available to demonstrate that the smoke seals will not adversely affect the overall fire resistance of timber door assemblies, when fitted in the proposed arrangements.



5. Limitations

This report addresses itself solely to the ability of the proposed assemblies described to satisfy the criteria of the fire resistance test and does not imply any suitability for use with respect to other unspecified criteria.

This document only considers the door assemblies described, herein, and assumes that the surrounding construction will provide no less restraint than the tested assembly and that it will remain in place and be substantially intact for the full fire resistance period.

This report is issued on the basis of test data and information to hand at the time of issue. If contradictory evidence becomes available, IFC reserves the right to withdraw the report unconditionally but not retrospectively.

As per the guidance outlined in the Passive Fire Protection Forum (PFPF): 'Guide to Undertaking Technical Assessments of Fire Performance of Construction Products Based on Fire Test Evidence, 2021, Industry Standard Procedure', appropriate action has been taken to mitigate the risk of a conflict of interest arising during the preparation of this report. All individuals involved in the production, or subsequent review, of this assessment have declared any perceived conflicts of interest, with regards to the sponsor or subject(s) of this report, prior to working on this project.

The assessor and reviewer have been deemed suitable for involvement in the production of this assessment in accordance with the guidance outlined in the Passive Fire Protection Forum (PFPF): 'Guide to Undertaking Technical Assessments of Fire Performance of Construction Products Based on Fire Test Evidence, 2021, Industry Standard Procedure'.

Where the constructional information in this report is taken from details provided to International Fire Consultants Ltd (IFC) and/or from fire resistance test reports referenced herein, it is, therefore, limited to the information given in those documents. It is necessarily dependent upon the accuracy and completeness of that information. Where constructional or manufacturing details are not specified, or discussed, herein, it should not, therefore, be taken to infer approval of variation in such details from those tested or otherwise approved.

The analysis and conclusions within this report are based upon the likely fire resisting performance of a complete door assembly that is manufactured and installed in accordance with this document, and offered for fire resistance testing in 'perfect' condition. In practice, management procedures must be in place in any building where the door assemblies are installed, to ensure that no parts of the assembly are damaged or faulty. Further, the doors must open and close without the use of undue force. The edge gaps/alignment of door leaves must be in accordance with the tolerances defined, herein, when the doors are closed. Any such shortfalls in respect to the condition of the assemblies will invalidate the approval by IFC, and may seriously affect the ability of the assemblies to provide the required level of fire resistance performance. Determination of what constitutes wear or damage, and any corrective actions in order to return assemblies to the required condition, should only be carried out following consultation with the manufacturer and IFC.

This report applies to fire door assemblies that are evaluated to BS476: Part 22: 1987; which is an applicable test method currently referenced within guidance to Building Regulations in the United Kingdom, and in building codes in some other countries. However, IFC have a duty of care to advise that introduction of CE Marking may become compulsory for fire resisting doorsets marketed in the EU, during the validity period of this report; in which case, users should contact IFC for further details/advice.

Where the assessed constructions have not been subject to an on-site audit by International Fire Consultants Ltd, it is the responsibility of anyone using this report to confirm that all aspects of the assemblies fully comply with the descriptions and limitations, herein.



Any materials specified in this report have been selected and judged primarily on their fire performance. IFC do not claim expertise in areas other than fire safety. Whilst observing all possible care in the specification of solutions, we would draw the reader's attention to the fact that during the construction and procurement process, the materials used should be subjected to more general examination regarding the wider Health and Safety, and CoSHH Regulations. Designers, manufacturers and installers are reminded of their responsibilities under the CDM Regulations; but particularly with regard to installation and maintenance of heavy or inaccessible items.

This assessment considers the fire resistance performance of the door assemblies when tested with the leaves in the closed position, within the frame reveal; either retained by the latch, or self-closing device, or locked shut, as applicable. The door assemblies will only provide the assessed fire performance when in a similar configuration; and it is the responsibility of the building occupants/owner to ensure that this is the case.

This report is provided to the sponsor on the basis that it is a professional independent engineering opinion as to what the fire performance of the construction/system would be should it to be tested to the named standard. It is IFC's experience that such an opinion is normally acceptable in support of an application for building approvals, certainly throughout the UK and in many parts of Europe and the rest of the world.

However, unless IFC have been commissioned to liaise with the Authorities that have jurisdiction for the building in question for the purpose of obtaining the necessary approvals, IFC cannot assure that the document will satisfy the requirements of the particular building regulations for any building being constructed.

It is, therefore, the responsibility of the sponsor to establish whether this evidence is appropriate for the application for which it is being supplied and IFC cannot take responsibility for any costs incurred as a result of any rejection of the document for reasons outside of our control. Early submittal of the Report to the Authorities will minimise any risks in this respect.

6. Validity

This Field of Application Report has been prepared based on International Fire Consultants Ltd's present knowledge of the products described, the stated testing regime and the submitted test evidence. For this reason, anyone using this document after February 2027 should confirm its ongoing validity.

This Field of Application Report is not valid unless it incorporates the declaration by the applicant given in Section 8 duly signed by the applicant.

Prepared by:

Chris Houchen BSc AlFireE Associate Director of Product Evaluation International Fire Consultants Ltd. (part of the Kiwa UK Group) Reviewed by:

David Cooper BEng (Hons) AIMMM AIFireE ACABE Director of Product Evaluation International Fire Consultants Ltd. (part of the Kiwa UK Group)



7. Declaration by the Applicant

Kiwa IFC Engineering Assessment Report	PAR/10899/01 Revision H			
Client	PKF Global Ltd			
We the undersigned confirm that we have read and complied with the obligations placed on us by the				
Passive Fire Protection Forum (PFPF) - Industry Standard Procedure 2021 'Guide to Undertaking Technical Assessments of Fire Performance of Construction Products Based on Fire Test Evidence'				
• We confirm that any changes which been tested to the standard again	h are subject of this assessment have not to our knowledge st which this assessment has been made.			
• We agree to withdraw this assessment from circulation should the component or element of structure, or any of its component parts be the subject of a failed fire resistance test to the standard against which this assessment is being made.				
• We understand that this assessment is based on test evidence and will be withdrawn should evidence become available that causes the conclusion to be questioned. In that case, we accept that new test evidence may be required.				
• We are not aware of any information that could affect the conclusions of this assessment. If we subsequently become aware of any such information, we agree to ask the assessing authority to withdraw the assessment.				
Signature	Enter			
Name				
Position				
Company Name	PKF Global Ltd			
Date				



Appendix A Leaf Size Envelopes and Intumescent Specifications







Leaf Configuration		Leaf Height	Leaf Width
		1951mm	1006mm
LJA	50	2562mm	727mm
		Transaction	Marco or an all the inter
Flush OV	erpanei	I ransomed Overpanel	Max Overpanel Height
×		\checkmark	1500mm
		Intumescent Specification	
Leaf Frame/Head	1no. 15 x 4mm intumescent seal centrally fitted in either the leaf head copposing frame reveal (can be increased to 20 x 4mm if required)		
Vertical Leaf Edges/Frame	1no. 15 x 4mm intumescent seal centrally fitted in either the leaf edge opposing frame reveal (can be increased to 20 x 4mm if required)		
jambs	opposing tran	ne reveal (can be increased to 20) x 4mm if required)
jambs Note: For appro	opposing fran	ne reveal (can be increased to 20 nt seal types, refer to Section 4.1	0 x 4mm if required) 12
jambs Note: For appro	opposing fram	ne reveal (can be increased to 20 nt seal types, refer to Section 4.:	0 x 4mm if required)
jambs Note: For appro	opposing fran	ne reveal (can be increased to 20 nt seal types, refer to Section 4.1	0 x 4mm if required) 12
jambs Note: For appro	opposing fran	ne reveal (can be increased to 20 nt seal types, refer to Section 4.:	0 x 4mm if required)
jambs Note: For appro	opposing fram	ne reveal (can be increased to 20 nt seal types, refer to Section 4.1	0 x 4mm if required) 12
jambs Note: For appro	opposing fram	ne reveal (can be increased to 20 nt seal types, refer to Section 4.:	0 x 4mm if required)





ULSASD

UNLATCHED SINGLE DOOR ASSEMBLIES



FD30



FIGURE A03

LATCHED DOUBLE DOOR ASSEMBLIES



Leaf Configu	uration	Leaf Height	Leaf Width
		2008mm	904mm
LSADI)	2281mm	768mm
Flush Over	panel	Transomed Overpanel	Max Overpanel Height
×		\checkmark	1000mm
		Intumescent Specification	
Leaf Frame/Head	1no. 20 x 4mm intumescent seal centrally fitted in either the leaf head or opposing frame reveal		
/ertical Leaf dges/Frame jambs	1no. 20 x 4mm intumescent seal centrally fitted in either the leaf edge or opposing frame reveal		
leeting edges	1no. 20 x 4mm intumescent seal centrally fitted in the closing edge of the active leaf only		tted in the closing edge of the
ote: For approved intumescent seal types, refer to Section 4.12			





Leaf Configuration		Leaf Height	Leaf Width	
		1988mm 896mm		
ULSAD	U	2259mm	760mm	
Flush Over	panel	Transomed Overpanel	Max Overpanel Height	
×		\checkmark	1000mm	
		Intumescent Specification		
Leaf Frame/Head	1no. 20 x 4mm intumescent seal centrally fitted in either the leaf head or opposing frame reveal			
Vertical Leaf Edges/Frame jambs	1no. 20 x 4mm intumescent seal centrally fitted in either the leaf edge or opposing frame reveal			
Meeting edges	1no. 20 x 4mm intumescent seal centrally fitted in the closing edge of the active leaf only			
Note: For approved intumescent seal types, refer to Section 4.12				



Appendix B Installation of hardware

B.1 Single Axis Hinges

ELEMEN	Г	SPECIFICATION/QUANTITY/DIMENSIONS			
Hinge Type	es	Fixed pin, washered butt, ball bearing butt, lift-off type or journal supported			
Blade Heig	ht	89 - 110mm			
Blade Widt	th	30 - 35mn	n		
Blade Thickn	iess	2.5 - 3.5m	m		
Material		Brass, Pho	osphor Bronze, Stee	l or Stainless Steel	
Fixings		Minimum	30mm long x 4mm	diameter steel screws	
Minimum Nur	mhor	Leaves up	to 2200mm high	3no. hinges	
	Iviinimum Number		ver 2200mm high	4no. hinges	
		Тор	125 - 175mm dow	n from the leaf head to the top of the hinge	
3no	3no	Middle	Either equi-space 150 – 250mm bel	Either equi-spaced between the top and bottom hinges or positioned 150 – 250mm below the top hinge	
		Bottom	175 - 250mm up from the bottom of the leaf to the bottom of the hinge blade		
Positions		Тор	125 - 175mm dow	n from the leaf head to the top of the hinge	
4no	Second and Third	Either equi-spaced between the top and bottom hinges or second hinge positioned 150 – 250mm below the top hinge and the third hinge equi-spaced between the second and bottom hinge			
		Bottom	175 - 250mm up f blade	rom the bottom of the leaf to the bottom of the hinge	
Intumesce Protection	nt า	Non required			
Additional Requirements/Notes		 Rising butts, cranked butts and spring hinges are not approved under the scope of this Assessment Single axis hinges must have been successfully type tested for conformity to all the requirements of BS EN 1935: 2002 including the additional requirements for fire/smoke door use 			
		• Single axis hinges must have a Door Mass Grade, as defined in BS EN 1935: 2002, which demonstrates the hinge is capable of supporting a door leaf weight, equal to, or greater than, that proposed.			



B.2 Mortice Locks/Latches

ELEMENT	SPECIFICATION/QUANTITY/DIMENSIONS		
Latch/Lock Type	Mortice latches, tubular mortice latches, sashlocks and deadlocks		
Maximum Forend Dimensions	235mm high x 22mm wide or 60mm high x 25mm wide		
Maximum Strike Plate Dimensions	235mm high x 24mm wide (excluding tongue) or 60mm high x 25mm wide (plus 31mm high x 15mm wide tongue)		
Maximum Body Dimensions	165mm high x 80mm wide x 15mm thick		
Material	Steel based with no essential part of the lock/latch to comprise polymeric or other low melting point (<800°C) materials and should not contain any flammable materials		
Position	Centred at 1000mm (± 200mm) above the bottom of the door leaf		
Intumescent	Forend/strike plate up to 152mm long	None required	
Protection	Forend/strike plate greater than 152mm long	2mm thick Interdens or Therm-A-Strip intumescent sheet fitted under the lock forend and strike plate	
Additional Requirements/Notes	 It is a condition of this assessment that there must be at least 50mm width of stile, or 'rail' between two apertures, between the lock/latch mortice and the glazed aperture. Over-morticing is to be avoided; mortices shall be as tight as possible to the latch. If there are gaps around the case (not exceeding 2mm) then these must be made good with intumescent mastic or sheet material. Holes for spindles or cylinders shall be kept as small as is compatible with the operation of the hardware Morticed locks/latches must have been successfully type tested for conformity to all the requirements of BS EN 12209: 2016 including the additional requirements for fire/smoke door use Mortice lock/latches must have achieved the appropriate Grade in respect of suitability of use in fire resisting doors, as defined in BS EN 12209: 2016. This constitutes Grade B for latched door configurations and Grade N for unlatched door configurations 		



B.3 Door Closers

GENERAL REQUIREMENTS/NOTES

Every hinged fire door (both leaves in double doors), including flat entrance doors and doors between a dwelling and an integral garage, must be fitted with a self-closing device, with the exception of the following;

- Fire doors which are normally kept locked shut and labelled with an appropriate sign which complies with BS5499: Part 1: 1990
- Fire doors to cupboards
- Fire doors within flats or dwellings

IFC recommends that the fire strategy for the proposed project is reviewed, as this may detail specific requirements for door closing devices, which takes precedence over the details outlined above.

This report evaluates the fire resistance performance of the doors assemblies when tested with the leaves in the closed position, within the frame reveal; either retained by the latch, or door closing device, or locked shut, as applicable. If no door closing device is fitted, good management practice must be in place to ensure the doors are fully closed into the frame reveal when not in use.

All door closing devices must be fitted according to the manufacturer's instructions (unless stipulated otherwise herein) and be adjusted so that they are capable of fully closing the door leaf, against any friction imposed by the latch (and smoke seals, if fitted), from any position of opening.

B.3.1 Surface Mounted Door Closers

GENERAL REQUIREMENTS/NOTES

Surface mounted door closers must have been fire tested or assessed by IFC for use on FD30 timber door leaves hung within timber frames

B.4 Flush Bolts

ELEMENT	SPECIFICATION/QUANTITY/DIMENSIONS
Maximum Size	152mm long x 19mm wide x 19-37mm deep
Material	Steel based with no essential part of the flush bolt to comprise polymeric or other low melting point (<800°C) materials and should not contain any flammable materials
Position	Positioned at the top and bottom of the vertical meeting edgeMust be located on the centre line of the leaf thickness
Intumescent Protection	None required



B.5 Push/Kick Plates

ELEMENT	SPECIFICATION/QUANTITY/DIMENSIONS
Maximum Dimensions	Maximum 0.2m ² per leaf face in any orientation
Fixing	Mechanically fixed with short screwsGlued with a thermally softening adhesive (e.g. contact adhesive)
Material	Steel or aluminium
Intumescent Protection	None required
Additional Requirements/Notes	 Must be cut short of door stops but may be located under the handle rose/ escutcheons Push/kick plates must be surface fixed only. These items must not be recessed into the leaf face

B.6 Surface Mounted Pull Handles

ELEMENT	SPECIFICATION/QUANTITY/DIMENSIONS
Max Dimensions	Fixing points must be no greater than 800mm apart
Material	Steel or aluminium
Intumescent Protection	Bolt-through fixings must be wrapped in 1mm thick Interdens/Therm-A-Strip or graphite based intumescent sheet material
Additional Requirements/Notes	Pull handles that are fixed through the leaf shall use clearance holes as close fitting as possible to the intumescent wrapped bolt

B.7 Door Selectors

ELEMENT	SPECIFICATION/QUANTITY/DIMENSIONS
Max Dimensions	No restrictions
Material	Steel or aluminium
Position	Surface mounted to the door leaf or frame
Intumescent Protection	None required
Additional Requirements/Notes	The installation of the door selector must not involve the removal of any material from the door leaf or door frame

B.8 Dropseals

ELEMENT	SPECIFICATION/QUANTITY/DIMENSIONS
Position	Bottom leaf edge - Fitted centrally in the leaf thickness.
Maximum Dimensions	35mm high x 14mm thick x full width of leaf
Intumescent Protection	Mortise lined with 1mm thick Interdens/Therm-A-Strip or graphite based intumescent sheet material



Appendix C Summary of fire test evidence

TEST REPORT	TEST SPONSOR	TEST LAB	TEST DATE	CONFIGURATION	LEAF SIZE	TEST STANDARD	RESULT	ITEMS/DETAILS SUPPORTED BY TEST EVIDENCE
CFR 1106291	PKF Global Ltd	Cambridge Fire Research	29/06/ 2011	ULSADD (opening in)	2040mm x 826/826mm x 42.5-43mm	BS476: Part 22: 1987	23 minutes* (33 minutes test terminated)	 3no. particleboard (550kg) core (14.5/15/14.5mm thick) = 43mm 24x10mm Oak inserts with 10x5mm groove, 2no. vertical + 2no. horizontal 33mm thick softwood (468-653kg) door frame with 12mm stop Oak (750-800kg) lips - vertical edges 10mm+6mm in 2 pieces, horizontal edges 8-10mm finger jointed 1406x390mm glazed ap, 7.3mm Pyroshield II glass + sapele chamfered bolection beads (40mm x 1.8mm pins @140mm centres @ 30degs to glass) + System 36 glazing channel(left leaf) Therm-A-Glaze 45(right leaf) R&T H105 hinges/152x22mm forend latch(101/61/15mm body)/Dorma TS68 surface closer/152x37x19mm disengaged flush bolts 20x4mm Lorient 617 intu in frame reveal + passive meeting edge
WF 350734	PKF Global Ltd	Warrington Fire	27/08/ 2015	ULSASD (opening in)	1981mm x 838mm x 44mm	BS476: Part 22: 1987	36 minutes	 3no. particleboard (700kg) core (3x13mm thick) = 39mm + 2.5mm thick MDF facing 23x7.5mm Oak inserts with 10x2.5mm groove (120mm from vert edges/117mm from head/185mm from bottom) 27mm thick softwood (532kg) door frame with 13mm stop Hardwood lips – 10mm vertical edges only, finger jointed and between MDF facings Eclipse 101x31mm blade hinges/60x25mm forend tubular latch (74/23/15mm body)/Assa Abloy surface closer 10x4mm Astroflame AF1004FS intu in frame reveal
CFR 1503101/01	PKF Global Ltd	Cambridge Fire Research	10/05 2015	ULSASD	1981mm x 839mm x 44mm	BS476: Part 22: 1987	45 minutes	 3 layers of particleboard (total 38thick) + 3mm thick MDF facing 30mm thick softwood (470kg) door frame with 25mm stop Meranti lips to all leaf edges 19-20mm vert edges + 8-12mm horiz edges 4.5mm wide x 1.8mm deep 'V' grooves in MDF facing (130mm from edge) and horizontally between vertical grooves) Glazed aperture lined with 7mm meranti (between facings) 1516 x 478mm glazed ap, 7.9mm Pyrosec EW 30/7 glass + sapele chamfered (45degree) bolection beads (40mm x 1.8mm pins @110-150mm centres @ 30degs to glass) + 10x2mm TAGlaze 45 44mm wide x 16-21.5mm thick Sapele 'mock' horizontal glazing bars, with/without intumescent, with/without pin fixings R&T H105 hinges/152x22mm forend latch(101/62/14mm body)/Briton surface closer 15x4mm Astroflame AF1504FO intu in frame reveal

* Premature failure occurred at 23 minutes due to ignition of the glazing beads in the left hand aperture. There was no leaf perimeter failure upon test termination at 33 minutes.



TEST REPORT	TEST SPONSOR	TEST LAB	TEST DATE	CONFIGURATION	LEAF SIZE	TEST STANDARD	RESULT	ITEMS/DETAILS SUPPORTED BY TEST EVIDENCE
CFR 1301221	PKF Global Ltd	Cambridge Fire Research	22/01/13	ULSADD	1982mm x 771/771 mm x 45mm	BS476: Part 22: 1987	38 minutes	• 30 x 71mm MDF (752kg) door frame with 12mm stop
CFR 1101201	PKF Global Ltd	Cambridge Fire Research	20/01/11	ULSASD	2040mm x 927mm x 44mm	BS476: Part 22: 1987	30 minutes	 914 x 337mm glazed ap, 7.5mm Pyrobelite glass + MDF (700-750kg) profiled bolection beads (40mm x 1.8mm pins @125-135mm centres @ 30degs to glass) Therm-A-Glaze 45 intumescent between bead and glass
CFR 2009211	PKF Global Ltd	Cambridge Fire Research	21/09/20	ULSASD (Door B only)	2040mm x 926mm x 44mm	BS476: Part 22: 1987	36 minutes (No failure)	 3no. layers of particleboard (550kg) core (15.5/12/15.5mm thick) = 43mm 15x10 + 12x8mm Oak inserts with 10x7 + 8x4mm grooves, 4no. full height vertical and 6no. horizontal (not full width) 30mm thick softwood (500kg) door frame with 12mm stop Hardwood lips – 6mm solid oak to vertical edges + 10mm finger jointed oak to horizontal edges, glued using PVA Rutland 101x30mm blade hinges(1mm Interdens) + Rutland 233x22mm forend latch(1mm Interdens) + 180x24strike(1mm Interdens) + 165/80/14mm body+1mm Interdens) + Rutland TS.11204.SR surface closer 15x4mm Pyroplex intu in frame reveal
CFR 2106041	PKF Global Ltd	Cambridge Fire Research	04/06/21	ULSASD (Door A only)	2039mm x 925mm x 43mm	BS476: Part 22: 1987	48 minutes (No failure)	 3no. layers of particleboard (550kg) core (13/13/13mm thick) = 39mm, UF glued + 3mm thick MDF (700kg) faces, UF glued + 0.13mm laminate faces, UF glued 5no. horizontal grooves formed using 15x10mm Oak(750kg) inserts (under MDF) with 10x7mm 'U' grooves, full width, 200mm from top/bottom and equally spaced between 4no. full width horizontal (403mm from top/bottom) and 5no. 403mm long vertical grooves (235mm from leaf vertical edges between horizontal V grooves) 6x1.5mm 'V' 30mm thick x 70mm deep softwood (480kg) door frame with 12mm stop Hardwood lips(750kg) – 39mm wide, 2no. 10mm solid oak to vertical edges + 1no. 10mm oak to horizontal edges, glued using UF between the MDF faces Rutland 102x31mm blade hinges(1mm Interdens) + Rutland 235x22mm forend latch (1mm Interdens) + 180x24strike(1mm Interdens) + 165/81/14mm body (1mm Interdens) + Rutland TS.11205.SR surface closer 15x4mm Mann McGowan intu in frame reveal
Chilt/ RF10070	CGI International Ltd	Chiltern Int'l Fire Ltd	27/05/10	LSASD	2040mm x 915mm x 44mm	BSEN 1634- 1: 2008 & BSEN 1363- 1: 1999	33 minutes	 44mm thick European redwood (510kg) door leaf 7mm Pyroguard Clear glass 900mm x 710mm 15mm high sapele beads with 21 degree chamfer fixed 50mm long screws, 70 from corners and at 200mm centres 10x2mm Interdens



TEST REPORT	TEST SPONSOR	TEST LAB	TEST DATE	CONFIGURATION	LEAF SIZE	TEST STANDARD	RESULT	ITEMS/DETAILS SUPPORTED BY TEST EVIDENCE
Chilt/ RF02106	Glaverbel (UK) Ltd	Chiltern Int'l Fire Ltd	19/02/03	ULSASD	2135mm x 915mm x 44mm	BSEN 1634- 1: 2000 & BSEN 1363- 1: 1999	37 minutes	 44mm thick European redwood (510kg) door leaf 7mm Pyrobelite 1835mm x 715mm 15mm high sapele beads with 15 degree chamfer fixed 50mm long screws, 50 from corners and at 150mm centres 12 x 3mm Papier Superwool X607 ceramic fibre tape
BMT/FEP/F 16200	Pilkington	EXOVA Warrington fire	05/07/16	ULSASD	2140mm x 900mm x 44mm	BSEN 1634- 1: 2015 & BSEN 1363- 1: 2012	37 minutes	 44mm thick European redwood (510kg) door leaf 7mm Pilkington Pyrodur 30-105 1824mm x 694mm 15mm high European redwood (510kg) beads with 15 degree chamfer fixed 40mm long x 1.9mm pins 50 from corners and at 150mm centres 15 x 3mm Zero Seals ceramic fibre tape. Flat glazing beads on side screens
CFR 1611081	Howdens	Cambridge Fire Research	08/11/16	LSASD (RH door only)	1980mm x 837mm x 44mm	BS476: Part 22: 1987	33 minutes	 3no. layers of particleboard (700kg) core+oak veneer = 44mm + 20mm thick oak lipping to vert edges(in 2 pieces)/10mm thick oak to horiz edges 6no. horizontal grooves formed using 23x6mm Oak(750kg) inserts with 6x4mm 'U' grooves, between vert grooves, 337mm from top/bottom and equally spaced between 2no. vertical (112mm from sides) for full height (same spec as horiz grooves) 30mm thick x 108mm deep softwood (450kg) door frame with 25mm stop Frisco Eclipse 102x32mm hinges ref HNG0025 Howdens Hoppe Arrone tubular latch 60x25mm forend latch + 60x41strike(incl 31x16 tongue) 23/15/72.5mm body No closer 15x4mm Astroflame AF1504FO into, central in frame reveal