

**NATIONAL
TYPE
APPROVAL**

Certificate No: 270-12-7090

Date: 27 September 2004

1 Certificate holder

Name: Astroflame Fireseals Ltd

Address: Unit 8 The I.O. Centre, Stephenson Rd, Segensworth, Fareham PO15 5RU

www.astroflame.com

Tel: 0800 019 7610

2 System Title

Description: Astro Strip FO, SB, TB, BS Intumescent Fireseals Astro Strip FS Fire and
Smoke Seals, Astro Projecta, Astro Liner System (Letterbox)

3 The system has been assessed on the following drawings and documents:

Fire test certification proving compliance in conjunction with appropriate fire door sets with Building
Regulation Part B, to the following standards:

30 Minutes : AF1004, 1204, 1504, (FO/ FS/ SB/ TB/ BS), Astro Liner Letter Box.

60 Minutes : AF 2004, 2504, 3004, 3804, (FO/ FS/ SB/ TB/ BS), Astro Liner Letter Box.

4 Assessment

The design and method of construction of the system described in (2) above has been examined and as far as
it has been shown has been found to be capable of complying with current Building Regulations.

5 Conditions of certification

- 1 The design shown and the materials specified shall not be changed without reference to the local authority responsible for certifying the system.
- 2 The certificate shall be valid for three years or until invalidated by formal notice.
- 3 Where reference is made on a plan to any Code of Practice, British Standard or manufacturer's instruction it shall be construed as a reference to such publication in the form in which it is in force at the date of the certificate.
- 4 This certificate should not be regarded as a formal approval under the Building Regulations.

6 Authority

This system approval certificate is authorised by:

Name: P. CHILVERS

Signature: P. Chilvers

on behalf of: LABC SERVICES