

Summary of Glass Impact Test Report
To BS EN 12150-1:2000 for Glass Safety

Test Consultant: **JAS (Inspection & Testing) Ltd.**

Manufacturer : **ESA SAFETY GLASS**

Report Ref. : J1999-R04EN-071017

Address : Jalan Kapt. Sumarsono 98, Helvetia, Medan, Indonesia.

Product Name : **Tempered Glass**
Tempered of the thicknesses: 4mm, 5mm, 6mm, 8mm, 10mm,
12mm, 15mm & 19mm.

Density : Approx. 2500 kg/m³


Specimen made into 1930mm x 865mm samples.

Test Results : Satisfactory

No. of Specimens Tested: 4 nos. for each thickness


Date of Test : 15th October 2007

Certified by



A handwritten signature in blue ink, consisting of a large, stylized 'S' followed by 'A', is written over a horizontal line. To the right of the signature is a red circular stamp with the text 'J.A. SHILLINGLAW C. ENG. R.P.E.' around the perimeter and '* CERTIFIED *' in the center.

Dr. J A Shillinglaw R.P.E.



The logo for JAS (Inspection & Testing) Ltd., featuring the letters 'JAS' in a bold, stylized, black font.