

Test Verification of Conformity

On the basis of the referenced test report(s), the sample(s) of the below product has been found to comply with the relevant harmonized standard(s) to the directive(s) listed on this verification at the time the tests were carried out.

The manufacturer may indicate compliance to said directive(s) by signing a DoC himself and applying the CE-marking to products identical to the tested sample(s). In addition, the manufacturer shall file and keep the documentation according to the rules of the applicable directive(s) and shall consider changes of the standard(s) if relevant. Additional requirements may be applicable such as additional directives or local laws.

Applicant Name & Address : Changshu Weier Glass Products Co., Ltd.
Haiyu Town, Changshu City, Jiangsu Province, China

Product(s) Tested : Tempered glass

Ratings and principal characteristics : Fragmentation test: Pass
Mechanical test: 192.4 N/mm²
Pendulum body impact resistance: Class 1(C)1

Model(s) : 4 mm thick

Brand name : /

Relevant Standard(s) / Specification(s) / Directive(s) : EN 12150-2:2004 (E)
89/106/EEC

Verification Issuing Office Name & Address : Intertek Testing Services Ltd. Shanghai JinQiao Branch
Building T52-8, No. 1201 Gui Qiao Road, Jinqiao Development Area, Pudong District, Shanghai, China 201206

Verification/Report Number(s) : Notified Body No.1139: 75/2013 and AU13014057-1

NOTE 1: This verification is part of the full test report(s) and should be read in conjunction with it.

NOTE 2: Pendulum body impact resistance was conducted by Notified Body No. 1139.

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification programme.



Signature

Name: Stanley Zhou

Position: Senior Manager

Date: March 29, 2013